

Engineering Specification:

Flexible Hoses / Connectors shall be made of stainless steel annular, close pitch braided hose, complete with male NPT nipples of required rating and material. Flexible Hoses / Connectors shall not be subjected to torque, axial extension or compression. Short style connectors shall be used in vibration applications only.

Approved Product: Model BSN, as manufactured by Mark David Canada Inc., Montreal, QC, Canada.

